

CERTIFICATE OF COMPLIANCE

Certificate Number 20181217-E345944
Report Reference E345944-20181210
Issue Date 2018-DECEMBER-17

Issued to: WATCHFUL EYE SOLUTIONS INC
332 Snake Hill Rd
Garrison NY 10524

This certificate confirms that representative samples of COMPONENT - SURGE-PROTECTIVE DEVICES
See Addendum page

Have been investigated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.


Standard(s) for Safety: ANSI/UL 1449 - Surge Protective Devices
CSA C22.2 No. 269.5 - SURGE PROTECTIVE DEVICES - TYPE 5 - COMPONENTS

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181217-E345944
Report Reference E345944-20181210
Issue Date 2018-DECEMBER-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Models/Product

Series: WTH-SG/TL20PG-320 Series

Cat No. - WTH-SG/TL20PG-320L,WTH-SG/TL20PG-320

Notes:

1. Suitable for Factory wiring only.
2. Suitable for Field and Factory wiring.
3. Series External Impedance required see Electrical Ratings in report.
4. Series External Overcurrent Protection required see Electrical Ratings in report.
5. Body of discrete component metal-oxide varistors (MOVs) flammability
 - a) min. V-0 or VTM-0.
 - b) min. V-1 or VTM-1.
 - c) Complies with IEC 60950-1, Edition 2.2, Annex Q/IEC62368-1 Annex G.8.2 needle flame testing requirements.
 - d) Complies with IEC 60065, Edition 7.2, Annex G.1.1 needle flame testing requirements.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

